



Summerland Street Exeter

Energy Statement Planning Issue

September 2023

Hulley & Kirkwood Consulting Engineers Ltd

2nd Floor, Studio 5 – 11

5 Millbay Road

Plymouth

Devon

PL1 3LF

(t): 01752 255 575

(e): hk.plymouth@hulley.co.uk

(w): www.hulley.co.uk

Prepared By: EK

Authorised By: SH

Revision: B

Project No: P0573

Date: September 2023

Summerland Street Exeter

Energy Statement

Planning Issue

September 2023

REV	DESCRIPTION	PREPARED BY	DATE
A	Initial Issue	EK	March 2023
B	Planning Resubmission	EK	September 2023

CONTENTS

Executive Summary	5
1.0 Introduction.....	6
1.1 Site Review.....	6
1.2 The Scheme Solution	6
2.0 Project Specific Energy and Carbon Emission Benchmarks	7
3.0 Passive/ Energy Reducing/ LZC & Renewable Energy Technology Options Appraisal	8
3.1 Passive Options.....	8
3.2 Good Practice Energy Saving Technology Options	10
3.3 Renewable and Low Zero Carbon Energy Technology Options	12
3.4 Selected Options	15
4.0 Energy Compliance Modelling	16
4.1 Energy Compliance Modelling Input Assumptions	16
4.2 Energy Compliance Modelling Outputs	17
5.0 Conclusion	18
Appendix A: Initial BRUKL Output Document.....	19

Executive Summary

This Energy Statement has been submitted to demonstrate compliance with the following energy and carbon project specific related drivers for the proposed Summerland Street development.

The energy and carbon project specific related drivers are:

- Building Regulations: Conservation of fuel and power - Approved Document Part L 2021, Volume 2: New buildings other than dwellings
- Exeter City Council (ECC) Core Strategy (adopted February 2012) and policies CP13, CP14 and CP15
- BREEAM UK New Construction (NC) Version 6.0, Ene 01 (Reduction of Energy Use and Carbon Emissions) “Excellent” Rating Performance

The above requirements are demonstrated in this statement by assessing the most appropriate options within three principal categories:

- Passive Options (*to maximise the energy efficiency of fabric*)
- Good Practice Energy Saving Technology Options (*to reduce the energy load of the development*)
- Low Zero Carbon/ Renewable Energy Technology Options (*to deliver on-site low carbon and/ or renewable energy systems*)

Section 3.0 outlines these options, highlighting that in addition to the passive measures and energy saving technologies proposed to be incorporated, the inclusion of air source heat pump(s) for providing heating and domestic hot water coupled with photovoltaic panels (including for future provision for district heating connection) will comply with the Building Regulations Part L 2021, relevant ECC policies’ and BREEAM UK NC Version 6.0 Ene 01 Excellent requirements.

1.0 Introduction

Hulley and Kirkwood Consulting Engineers have been appointed to provide a statement for the proposed Summerland Street development to demonstrate the recommended means of compliance with the relevant Exeter City Council planning policies.

1.1 Site Review

The project includes for the demolition of existing buildings and the erection of a 147 bed-space co-living development (up to 6 storeys in height) and associated work.

The building has been assessed to include low carbon and renewable energy generation to achieve reduced energy and carbon emission levels.

The key energy requirements of the development arise from the heating and hot water demands and the electrical load associated with both the building operation and plug-in loads. Proposals should address the hot water demand, heat load and/or the electrical loads of the development.

1.2 The Scheme Solution

The current scheme adopts a passive approach coupled with energy saving technologies to minimise the energy usage, where possible. The envelope will be highly insulated and air tight for minimising the heating energy consumption.

Section 3.0 details an assessment of the LZC/ renewable technologies that have been considered for the site with explanations of which technologies are considered suitable for further development, and which have been excluded due to the site constraints and suitability for the project.

The recommended options to be developed during the design stage are:

- Air Source Heat Pump(s) (ASHPs) (air to water) for heating and hot water
- Photovoltaic Panels (PVs)
- Future provision for district heating connection

Exact sizes of the ASHP(s) to be determined at detailed design stages.

2.0 Project Specific Energy and Carbon Emission Benchmarks

The servicing strategy is driven by the following energy and carbon project specific requirements:

- **Building Regulations:** Conservation of fuel and power - Approved Document Part L 2021, Volume 2: New buildings other than dwellings.
- **Exeter City Council Core Strategy** (adopted February 2012) and relevant policies, i.e.:

Policy CP13 Decentralised Energy:

CP13: Decentralised Energy Networks will be developed and brought forward. New development (either new build or conversion) with a floorspace of at least 1,000 square metres, or comprising ten or more dwellings, will be required to connect to any existing, or proposed, Decentralised Energy Network in the locality to bring forward low and zero carbon energy supply and distribution. Otherwise, it will be necessary to demonstrate that it would not be viable or feasible to do so. Where this is the case, alternative solutions that would result in the same or better carbon reduction must be explored and implemented, unless it can be demonstrated that they would not be viable or feasible.

Policy CP14 Renewable and Low Carbon Energy:

New development (either new build or conversion) with a floorspace of at least 1,000 sq. metres, or comprising ten or more dwellings, will be required to use decentralised and renewable or low carbon energy sources, to cut predicted CO₂ emissions by the equivalent of at least 10% over and above those required to meet the building regulations current at the time of building regulations approval, unless it can be demonstrated that it would not be viable or feasible to do so.

Policy CP15 Sustainable Construction:

All non-domestic development will be required to achieve BREEAM 'Very Good' standards increasing to 'Excellent' standards from 2013. Non-domestic buildings are expected to be zero carbon from 2019.

- BREEAM UK New Construction Version 6.0, Ene 01 (Reduction of Energy Use and Carbon Emissions) 'Excellent' rating minimum performance standards.

3.0 Passive/ Energy Reducing/ LZC & Renewable Energy Technology Options Appraisal

This section reviews and analyses the principal sustainable and low zero carbon/ renewable technologies that are deemed appropriate for the proposed development.

Key:

☆ = low ☆☆☆☆☆ = high

3.1 Passive Options

This category recommends the investigation of the site layout, building orientation and design, thermal insulation levels and construction practices, all of which are proposed to be incorporated within the development proposals.

These proposals will result in minimising the development's energy consumption/carbon footprint by reducing solar overheating (avoiding comfort cooling where possible) and decreasing heat losses (fabric and infiltration), while maximising natural daylight.

Item	Description	Suitability	Capital Cost
Increased Insulation	Increased thermal insulation to the building reduces heat losses and subsequently plant sizing. The targeted U-values for the proposed development are in excess of BRs Part L 2021 values and therefore can result in reduced heating energy consumption. The average U-values for all elements of the proposed new building are recommended as below: • External Walls: 0.15 W/m²K • Ground Floor: 0.14 W/m²K • Roof: 0.15 W/m²K • Glazing: 1.4 W/m²K ○ All areas- g value: 0.48, light transmittance: 0.76* ○ Ground floor areas and top floor KLD - g value: 0.28, light transmittance: 0.60* <i>* in line with the initial Overheating: Approved Document O assessment carried out for the project</i>	☆☆☆☆☆	☆☆
Construction Processes	The Building Regulations require a maximum of 8 m³/h/m² at 50 pascals for the air leakage rates from a new building; the lower this figure the less energy is lost from the inside of a building to outside.	☆☆☆☆☆	☆

	With good construction processes and approved thermal bridging values incorporated it is anticipated that an infiltration rate of 3 m³/h/m² at 50 Pascals can be targeted.		
Window Design	In addition to consideration of the site layout, and building orientation/design, increased levels of glazing (window design) allows more daylight to enter a building, potentially reducing the dependency upon artificial light and provide better well-being of the occupants. Optimum window sizes when combined with efficient lighting controls can offer increased energy savings. An initial Overheating: Approved Document O assessment has been completed to ensure that the proposals cover the overheating mitigation requirements of the building regulations.	☆☆☆☆☆	☆☆

3.2 Good Practice Energy Saving Technology Options

This category extols the benefits of employing energy saving technologies considered appropriate to be incorporated within the development proposals.

Item	Description	Suitability	Capital Cost
Inverter Controlled Pump Motors	The close matching of pump power to the required pump performances will provide significant reductions in (electric) energy demand. The primary and secondary circulation pumps within the development present a good opportunity to achieve these reductions.	☆☆☆☆☆	☆☆
Comprehensive Sub-Metering Facilities	The installation of sub-meters correctly located within building services systems can provide essential information regarding energy usage, permitting close monitoring (and hence reducing energy wastage) to be achieved. It is proposed to provide energy usage and monitoring also in line with the BREEAM UK NC Version 6.0 requirements.	☆☆☆☆☆	☆☆
Water Flowrate Regulation	The reduction of water usage/wastage is obviously important, and combined with a saving in the energy used to heat the water makes this option more attractive. The regulation of water flowrates to appliances are proposed to be incorporated within the water services.	☆☆☆☆☆	☆

Lighting Design	High efficiency luminaires utilising long life lamps with dimmable low loss ballasts / LED technology provide an effective energy saving over conventional luminaires. LED technology is proposed to be incorporated throughout the development, with presence linked control within general and circulation areas.	☆☆☆☆☆	☆☆☆
-----------------	--	-------	-----

3.3 Renewable and Low Zero Carbon Energy Technology Options

The following renewable and/ or low zero carbon energy technologies were given initial consideration for use within the scheme. The reasons for excluding certain technologies or including for further assessment are listed below.

Item	Description	Suitability	Capital Cost
Wind Turbines	Electrical generation from wind turbine units, either individually or grouped together to form a 'wind farm'. Wind turbines are also available in a scaled down form that can be mounted on buildings. Due to the limited site area, the wind turbine(s) would have to be located on the top of the proposed development, resulting in significant visual impact. The restricted site and location do not render this option worthy of further consideration.	☆	☆☆☆
Solar Thermal Panels	External panels which can be mounted on the roof or in an open space through which a medium is passed to absorb heat energy from the sun. The heat can be used to supplement a development's hot water production. This option has benefits to the scheme, as there will be demand for hot water within the building. However, the visual impact and reflections on the surrounding areas will need to be assessed. Also, additional plant space will be required for placing the pre-heating buffer vessels. Therefore, this technology is not deemed appropriate for the building.	☆☆☆	☆☆☆☆
Photovoltaic Panels	External panels which can be mounted on the roof or integrated into the façade of buildings, or in any open space, subject to planning permission. The panels convert the energy of the sun directly into electricity. The electricity can be used to supplement the building's power supply. PV panels are deemed to be an appropriate technology for this development (especially for offsetting the energy required to run the air source heat pump(s)), although the visual impact and estimated service/ access space requirements would need to be addressed.	☆☆☆☆	☆☆☆

Biomass Boiler	Biomass boilers burn biological material such as wood pellets or logs in place of fossil fuels to serve the heating and hot water demands of a development. Pellet or chip biomass boilers generally have a hopper attached in which the fuel is loaded and automatically feeds into the boiler. The hopper will need to be refilled on a regular basis depending on demand and the size of the hopper. Log boilers typically require manual loading at an increased frequency due to the need for positioning the logs correctly. A steady fuel source is vital, ideally within a 50mile radius, so that carbon emission reductions are not cancelled out by transport pollution. Biomass boilers require constant maintenance and attention to ensure that they are working correctly and efficiently. Therefore, there are significant logistical, operational and storage implications. Additional plant space for the biomass boiler and its storage would also be required. For the above reasons this technology is not deemed appropriate for the development.	☆☆	☆☆☆☆
Combined Heat & Power CHP	CHP is a process that uses a fuel source to generate electricity and utilises the heat produced as a by-product to meet a heating demand. The fuel for this process is typically natural gas, but can also be biogas, biomass, gas oil, or hydrogen fuel cells, amongst others. The electricity generated can be utilised by the building operators or exported to the grid, or a combination of the two. There is a Client preference for eliminating the use of gas, therefore this technology is not deemed appropriate for the development.	☆☆☆	☆☆☆
Centralised District Heating	A district heating system, or heat network, is a system for distributing heat to different residential or commercial properties. The heat is generated at a centralised location and can be extended to serve a particular development or building via below ground pipework and a heat exchanger. The heat can be used to satisfy a building's heating and hot water demand. Currently there are no appropriate district heating schemes in the local vicinity. However, future provision connection can be incorporated in the scheme.	☆☆☆☆	☆☆

Ground Source Heat Pumps (GSHP)	A technology that uses the constant temperature of the ground to provide low grade hot water for use in building heating systems. Pipework is buried in the ground either in a horizontal 'slinky' configuration or a vertical 'u-tube' utilising bore holes. Water is passed through the ground loops where it absorbs the heat from the ground. The water is used to raise the temperature of a refrigerant which is in turn elevated further by the heat pump to provide heat to the heating system. A large area of surrounding land would be required to make this option viable, or a 'pile' arrangement could be considered depending upon ground conditions. The site would experience significant external disruption, as well as high associated capital cost. Therefore, the use of a GSHP is not deemed appropriate for the scheme.	☆☆	☆☆☆☆
Air Source Heat Pumps (ASHP)	An ASHP is a refrigerant based system that absorbs or rejects heat from/to the external air. In air-to-water systems the refrigerant passes through a heat exchanger to provide hot or chilled water for either space heating, domestic hot water generation or comfort cooling. In air-to-air systems the heat exchanger transfers the heat to air. Direct expansion (DX) split units provide either heating or cooling to one zone/appliance. Variable Refrigerant Flow (VRF) systems can provide simultaneous heating and cooling to multiple areas at the same time. With the reductions in the carbon emission factor of electricity, ASHP(s) are considered a viable and future proof alternative to gas in terms of total carbon footprint. However, consideration will need to be given to electrical infrastructure upgrades for the increased load demand. For the above reasons this technology is deemed appropriate for the development.	☆☆☆☆	☆☆☆

From an initial review of the project against the options highlighted above, it is recommended that the following low zero carbon and renewable technologies are considered for implementation within this scheme:

- Air Source Heat Pump(s) for heating and hot water (the exact size is to be determined at detailed design stages)
- Photovoltaic Panels (PVs)
- Future provision for district heating connection

3.4 Selected Options

After careful assessment the following options are considered to be the most appropriate and practicable, and are recommended to be incorporated within this scheme;

Passive Options

- Increased thermal insulation
- Low air infiltration losses
- High levels of natural daylight

Good Practice Energy Saving Technologies

- Inverter driven motors, for variable power output matched to actual usage (not on/off)
- Comprehensive sub-metering facilities
- Water flowrate regulation
- Lighting controls incorporating presence linking
- Low energy LED lamp technology

Low Zero Carbon/ Renewable Technologies

- Air Source Heat Pump(s) for heating and hot water
- Photovoltaic Panels (PVs)
- Future provision for district heating connection

4.0 Energy Compliance Modelling

Preliminary BRUKL (Building Regulations Part L 2021) calculations using dynamic simulation modelling (IESVE) have been carried out by incorporating the passive, good practice energy saving and LZC/ renewable energy options as described in Section 3.0.

4.1 Energy Compliance Modelling Input Assumptions

To provide an understanding of the inputs/ assumptions, the principal design criteria used to produce the proposed energy compliance model are as follows:

Input	Proposed
Building Regulations:	England Building Regulations Part L 2021
BRUKL compliance check version:	V6.1. e.1
Calculation engine version:	7.0.22
Location:	Exeter
Compliance weather file:	PLYMOUTH_TRY.epw (compliant weather file closest to site)
Model geometry	Model geometry based on proposed Architectural planning drawings
Air permeability @50pa	3 m ³ /(h.m ²)
U-values	Glazing: 1.4 W/(m ² K) [inc. frame] All areas- g value: 0.48, light transmittance: 0.76 Ground floor areas and top floor KLD - g value: 0.28, light transmittance: 0.60 Rooflights: 2.1 W/(m ² K) External walls: 0.15 W/(m ² K) Roof: 0.15 W/(m ² K) Ground floor: 0.14 W/(m ² K) Doors: 1.6 W/(m ² K)
Lamp efficacy and lighting controls for all areas:	105 lm/cW (average) with presence detection in circulation areas
Ventilation strategy	MVHR in all occupied areas • Studios: SFP 1.1 W/l/s, heat recovery efficiency: 90% or better • KLDs: SFP 1.0 W/l/s, heat recovery efficiency: 87% or better • Ground Floor Non-standard accommodation areas: SFP 1.3 W/l/s, heat recovery efficiency: 85% or better
Power factor correction unit:	YES
Building Management System (warn out of range values):	YES
ASHP(s) SCOP	3.3 or better for heating 3.4 or better for hot water
VRV in non-standard accommodation areas and KLDs	SCOP: 3.5, SEER: 5.0, EER: 3.5
PV system	Generating 26,500 kWh/annum (subject to detailed design, requirement may reduce)

4.2 Energy Compliance Modelling Outputs

Based on the inputs detailed in Section 4.2 and subject to detailed design, it is anticipated that 7 credits (in excess of the minimum Ene 01 requirements for Excellent rating) can be achieved under Ene 01 BREEAM UK NC Version 6.0.

Target CO ₂ Emission Rate - TER (kgCO ₂ /m ² .annum)	Building CO ₂ Emission Rate – BER (kgCO ₂ /m ² .annum)	Expected EPC Rating	Policy CP14 10% Carbon Offset Achieved?	Policy CP 15 Ene01 'Excellent' rating achieved?
2.96	2.64	A	YES (11%)	YES (7 credits and an EPR of 0.727)

5.0 Conclusion

The proposed scheme (as detailed in this report) is expected to comply with the following energy and carbon project specific related drivers:

- **Building Regulations:** Conservation of fuel and power - Approved Document Part L 2021, Volume 2: New buildings other than dwellings
- **Exeter City Council Core Strategy** (adopted February 2012) and relevant policies, i.e.:
 - **CP13:** The requirements of Policy CP13 are achieved based on future provision for district heating connection.
 - **CP14:** The requirements of Policy CP14 are achieved based on compliance with the relevant to the scheme Part L requirements as detailed above with the inclusion of renewable (PVs) and low carbon energy sources ASHP, to cut predicted CO₂ emissions by the equivalent of at least 10% over and above those required to meet the building regulations current at the time of building regulations approval.
 - **CP15:** The proposed development achieves the Ene 01 (Reduction of energy use and carbon emissions) 'Excellent' rating minimum performance standards under the BREEAM UK New Construction Version 6.0 scheme.

Appendix A: Initial BRUKL Output Document

BRUKL Output Document



Compliance with England Building Regulations Part L 2021

Project name

Summerland Street

As designed

Date: Wed Aug 23 11:50:49 2023

Administrative information

Building Details

Address: Summerland Street, Exeter,

Certifier details

Name: Eleni Kalyva

Telephone number: 01752255575

Address: Hulley & Kirkwood, Studio 5-11, Millbay Road,
Plymouth, PL1 3LF

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 792.55The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	2.96
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	2.64
Target primary energy rate (TPER), kWh _{ep} /m ² annum	31.8
Building primary energy rate (BPER), kWh _{ep} /m ² annum	28.08
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER BPER ≤ TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _a -Limit	U _a -Calc	U _i -Calc	First surface with maximum value
Walls*	0.26	0.16	0.35	FC000000:Surf[7]
Floors	0.18	0.15	0.29	BT000010:Surf[2]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.15	0.15	ST000020:Surf[0]
Windows** and roof windows	1.6	1.4	1.6	CC000000:Surf[3]
Rooflights***	2.2	2.1	2.1	FC000000:Surf[3]
Personnel doors^	1.6	1.6	1.6	CC000001:Surf[3]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building
U _a -Limit = Limiting area-weighted average U-values [W/(m ² K)] U _a -Calc = Calculated area-weighted average U-values [W/(m ² K)] U _i -Calc = Calculated maximum individual element U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/m ² K. NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	3

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters			Building Use	
	Actual	Notional	% Area	Building Type
Floor area [m ²]	4822.4	4822.4		Retail/Financial and Professional Services
External area [m ²]	5124.5	4967.8		Restaurants and Cafes/Drinking Establishments/Takeaways
Weather	PLY	PLY	15	Offices and Workshop Businesses
Infiltration [m ³ /hm ² @ 50Pa]	3	3		General Industrial and Special Industrial Groups
Average conductance [W/K]	1877.06	1886.59		Storage or Distribution
Average U-value [W/m ² K]	0.37	0.38		Hotels
Alpha value* [%]	29.54	10		Residential Institutions: Hospitals and Care Homes
* Percentage of the building's average heat transfer coefficient which is due to thermal bridging				Residential Institutions: Residential Schools
				Residential Institutions: Universities and Colleges
				Secure Residential Institutions
			85	Residential Spaces
				Non-residential Institutions: Community/Day Centre
				Non-residential Institutions: Libraries, Museums, and Galleries
				Non-residential Institutions: Education
				Non-residential Institutions: Primary Health Care Building
				Non-residential Institutions: Crown and County Courts
				General Assembly and Leisure, Night Clubs, and Theatres
				Others: Passenger Terminals
				Others: Emergency Services
				Others: Miscellaneous 24hr Activities
				Others: Car Parks 24 hrs
				Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	3.13	3.58
Cooling	0.22	0.15
Auxiliary	3.31	1.78
Lighting	5.95	6.28
Hot water	11.78	9.59
Equipment*	12.88	12.88
TOTAL**	24.39	21.4

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	5.49	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>5.49</i>	<i>0</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	40.65	38.41
Primary energy [kWh _{PE} /m ²]	28.08	31.8
Total emissions [kg/m ²]	2.64	2.96