

Luminaire Schedule						
Index	Manufacturer	Luminaire Type	Luminous Flux	Mounting height(m)	Connected Load	Colour Temp (K)
X1	Thorn	D-CD LED	608 lm	Inground	12 W	3000
X2	Fagerhult	Opalume	7681 lm	4	50.3W	3000
X3	Thorn	Urba Bollard LED	826 lm	1	16 W	3000
X4	Thorn	Satin 2 LED	1019 lm	Inground	15 W	3000
X5	Thorn	Alumet LED	1709 lm	4	21 W	3000
X7	Thorn	Piazza LED	1844 lm	2.7	16 W	3000
X8	Bega	24813	4381 lm	Stair/Ramp	31.6W	3000
X9	Thorn	Linn LED	436 lm	Stair/Ramp	11.3 W	3000

Design Criteria			
#	Name	Average	Uo
1	Pedestrian Walkway 1	5 Lux	0.25
2	Road to Underground Parking	10 Lux	0.25
3	Urban Oasis Garden	20 Lux	0.25
4	Courtyard Garden	20 Lux	0.25
5	Walk path 1	5 Lux	0.25
6	Walk path 2	5 Lux	0.25

KEY PLAN

ISOLINE

0.5 Lux

1 Lux

5 Lux

10 Lux

20 Lux

50Lux

NOTES

1. ALL DIMENSIONS ARE TO BE CHECKED ON SITE BEFORE THE COMMENCEMENT OF WORKS. ANY DISCREPANCIES ARE TO BE REPORTED TO THE ARCHITECT & ENGINEER FOR VERIFICATION. FIGURED DIMENSIONS ONLY ARE TO BE TAKEN FROM THIS DRAWING.

2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEERS' AND SERVICE ENGINEERS' DRAWINGS AND SPECIFICATIONS. THIS DRAWING IS COPYRIGHT.

3. PLEASE REFER TO LUMINAIRE SCHEDULE FOR LUMINAIRE TYPES, COLUMN HEIGHT AND QUANTITIES ON THE DRAWING WITH THE TABLE PROVIDED.

4. BUILDING MOUNTED LUMINAIRES SHALL BE PROVIDED WITH A PHOTOCELL.

5. LIGHTING TO BE IN LINE WITH BS EN 12464-2 STANDARDS FOR OUTDOOR PLACES.

REVISIONS

Suitable for Stage Approval				
PD8	AP	24/10/19	GR	24/10/19
Suitable for Review & Comment				
PD3	AP	26/09/19	GR	26/09/19
Suitable for Review & Comment				
PD2	AP	20/09/19	GR	20/09/19
Suitable for Review & Comment				
PD1	AP	27/06/18	GR	27/06/18
REVISION NOTES/COMMENTS				
REV	DRAWN BY	DATE	CHECKED BY	DATE

Hydrock

5-19 Cowbridge Road East
CARDIFF
CF11 9AB

1-44102920 023655
e: cardiff@hydrock.com

CLIENT

Curlew Alternatives Property LP

PROJECT

The Harlequins Centre

TITLE

Electrical Services
External Lighting Strategy
Ground Floor

HYDROCK PROJECT NO.		SCALE @ A0	
C-09377		1 : 200	
STATUS DESCRIPTION		STATUS	
SUITABLE FOR STAGE APPROVAL		S4	
DRG NO. (PROJECT ORIGINATOR VOLUME-LEVEL-TYPE-ROLE-NUMBER)	REVISION	REVISION	
EHQ-HYD-XX-00-DR-ME-00010		P04	