

McCulloughs Ltd Unit 5D, Victoria Way Newmarket Suffolk, CB8 7SH

Tel: 01638 666489 Fax: 01638 663133 Email: rob@mcculloughs.co.uk

5th July 2019

Turks Head 202 High Street Exeter EX4 3EB

ODOUR CONTROL ASSESSMENT

Assessment is based on DEFRA Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust systems January 2005

Page 57 - Table 4.7 summaries the required residence times for various cooking processes

Application	Capacity Required	Residence Time (seconds)
Canteen, normal kitchen and	'Normal'	0.1 – 0.2
restaurants		

Dispersion Moderate

Discharging 1m above eaves at 10 - 15m/s Score 10

Proximity of Receptors Close

Receptor less than 20m from discharge Score 10

Size of Kitchen Large

More than 100 covers Score 5

Cooking Type High Score 10

Score Total 35

High Risk - High Odour Control

Proposal

Baffle Filters within canopy.

2no Purified Air ESP 3000 Units.

1no Carbon filtration unit. (0.2 second residence time.)