

Contractors to check all dimensions on site.
Any discrepancies must be reported to the
supervising officer before proceeding.
Do not scale from this drawing. Work from
figured dimensions only
This drawing must be read in strict
conjunction with all construction details,
specifications of works, and all relevant
structural and other consultants drawings.
This drawing © Kensington Taylor Architects

EGRESS TIMES

total vomitary width = 7.100m @ A B & C
82 people per m width (per the Green Guide)
West Stand seated 7.100m width x 82 = 582
total = 4283 spectators 4377/582 = 7mins 52secs
disabled = 56 + 38 carers
overall = 4377

EGRESS TIMES

total vomitary width = 4m @ A & B
66 people per m width (per the Green Guide for stepped exit)
South West Corner 4m width x 66 = 264
total = 1340 spectators 1340/264 = 5min 7secs

EGRESS TIMES

total vomitary width = 2.5m @ A
82 people per m width (per the Green Guide)
North West Corner 2.5m width x 82 = 205
total = 1510 spectators 1510/205 = 7min 36secs

EGRESS TIMES

total vomitary width = 10m @ A & B
82 people per m width (per the Green Guide)
South Stand 10m width x 82 = 820
total = 3212 spectators 3260/820 = 4min 40secs
disabled = 29 + 19 carers
overall = 3260

CAPACITY FIGURES

WEST STAND = 4377	
SOUTH STAND = 3260	incl disabled & carers
EAST STAND = 4876	WEST STAND = 58
NORTH STAND = 3146	NORTH STAND = 27
N/W CORNER = 1510	EAST STAND = 36
N/E CORNER = 1104	SOUTH STAND = 29
S/E CORNER = 1067	<u>TOTALS = 150</u>
S/W CORNER = 1340	
<u>TOTAL = 20,680</u>	

EGRESS TIMES

total vomitary width = 6m @ A,B & C
82 people per m width (per the Green Guide)
North Stand 6m width x 82 = 492
total = 3100 spectators 3146/492 = 6min 39secs
disabled = 27 + 19 carers
overall = 3146

EGRESS TIMES

total vomitary width = 4m @ A & B
66 people per m width (per the Green Guide for stepped exit)
South East Corner 4m width x 66 = 264
total = 1067 spectators 1067/264 = 4min 4secs

EGRESS TIMES

upper tier total vomitary width = 6.4m @ A,B,C & D
66 people per m width (per the Green Guide)
East Stand seated 6.4m width x 66 = 423
total = 1796 spectators 1868/423 = 4min 41secs
disabled = 36 + 36 carers
overall = 1868

EGRESS TIMES

lower tier total vomitary width = 8.7m @ A,B & C
82 people per m width (per the Green Guide)
East Stand standing 8.7m width x 82 = 714
total = 3008 spectators 3008/714 = 4min 20secs

EGRESS TIMES

total vomitary width = 2.5m @ A
66 people per m width (per the Green Guide for stepped exit)
North East Corner 2.5m width x 66 = 165
total = 1104 spectators 1104/165 = 7min 9secs

PLEASE READ INCONJUNCTION WITH
DWG no 1032 L05.01

REV.	DATE	DESCRIPTION	DRAWN	CHECKED
A	21.06.2012	DISABLED FIGURES REVISED	RG	JL
TITLE				
EXETER RUGBY CLUB				
SANDY PARK, EXETER.				
DETAIL				
EGRESS TIMES				
SCALE	DATE	DRAWN BY	CHECKED BY	
1:500	NOV 11	RG		
DRAWING NO.	REVISION			
1032 PL05.02	A			
FILE NAME: 51123	PLOT DATE: 5/11/2011			

Kensington Taylor
CHARTERED ARCHITECTS • CHARTERED DESIGNERS

KT

Kensington Court
Woodwater Park
Pyms Hill
Exeter EX2 5TY
T 01392 360338 F 01392 360344
E mail: kt@kensingtontaylor.com
W www.kensingtontaylor.com

QMF 18 Issue 2 15-01-2008

egress times

PLANNING ISSUE